

CHAPTER XXVIII

ELECTRICAL CODE

28.01 National Electrical Code and Wisconsin Electrical Code Adopted

28.02 Permit

28.03 Inspection of Work

28.04 Utilities Commission Regulations

28.05 Service Entrance Rating

28.01 NATIONAL ELECTRICAL CODE AND WISCONSIN STATE ELECTRICAL CODE ADOPTED. All electrical work, including the placing of wires and other equipment, shall conform to the National Electrical Code and the Wisconsin State Electrical Code, Chapter IHLR 16 of the Wisconsin Administrative Code, as those provisions may be amended from time to time, both of which are adopted by reference and made a part of this chapter as though set forth in full herein. If there is a conflict between the provision of the national Electrical Code and the Wisconsin State Electrical Code, the provision of the Wisconsin State Electrical Code shall control. A copy of the National Electrical Code shall be kept in the offices of the Village Clerk and the Village Building inspector for public inspection.

28.02 PERMITS AND PERMIT FEES. No electric wiring or other equipment shall be installed or altered without first securing a permit therefore from the Building Inspector, except that repairs or replacements may be made without a permit. The application for such permit shall be on a form furnished by the Building Inspector and shall state clearly the work planned, alterations to be made, and equipment must be submitted to and approved by the Building Inspector. The schedule of fees for each permit shall be set periodically by Resolution of the Board of Trustees.

28.03 INSPECTION WORK. After roughing in the wiring of any building and before any such work is covered up, or upon completion of any outside wiring construction work, the person doing the work shall notify the Building Inspector who shall at once inspect the work. Upon completion of wiring, the Building Inspector shall be notified and he shall inspect the finished work. If he finds that the work conforms to the National Electrical Code, he shall issue a certificate of compliance which shall contain the date and an outline of the result of such inspection, a duplicate of which shall be on file in his office. No person shall use any electrical equipment until a certificate of compliance has been issued.

28.04 UTILITIES COMMISSION REGULATIONS. All electrical work in the Village shall also be done in conformity with the service rules and regulations of the Utilities Commission as filed with the Wisconsin Public Service Commission.

28.05 SERVICE ENTRANCE RATING. Minimum single phase service entrance and meter socket permitted to be installed shall be rated 100 ampere, 3 wire, 120/240 volt. Service connections on the building shall be at least 14 feet above the ground and shall be brought out on the side of the building most readily accessible from the nearest pole.